

NO.NC/QC/YD/2020-21/YSD-CC

Date: 20-05-2020

To,
The Executive Engineer,
Yelahanka Division
Bangalore.

"PMC CERTIFICATE AND INSPECTION REPORT"

Dear Sir,

Subject: Regarding Inspection Report for the below mentioned work.

Name of Work: Construction of CC road in Ward No. 03 Attur, Yelahanka

Item	Description of work	Unit	Qty
1	KSRRB M200-24. Dismantling of cement concrete pavement by mechanical means using pneumatic tools, breaking to pieces not exceeding 0.02 cum in	Cum	313.73
2	KSRRB M300-14. Excavation for roadwork in all types of soil by mechanical means including cutting and loading to tippers, trimming bottom and side	Cum	241.61
3	Construction of granular sub-base Grading-V as Sub-base and drainage layer by providing coarse graded crushed stone aggregates of granite/ trap/basalt	Cum	91.40
4	KSRRB M2100-10. Providing and laying Plain cement concrete of mix 1:3:6 with OPC @ 220kgs, with crushed 40mm and down size graded granite metal	Cum	241.92
5	Constructing un-reinforced, plain cement concrete for pavements using Grade concrete M30 with OPC at 360 kg/cum and coarse aggregate 0.69cum, fine	Cum	235.30
6	Providing and fixing pre cast solid cement concrete kerb stones made out of C.C. 1:2:4 with top and bottom width 114 and 165 mm respectively, 400mm	Nos	735.00
7	KSRRB 800-1. Painting two coats after filling the surface with synthetic enamel paint in approved shades on new plastered concrete surfaces, with materials,	Sqm	206.54
8	Removing & Refixing stone slabs of drains and pointing in C.M (1:3)	Sqm	274.80
9	Providing and fixing Precast RCC cover slabs of 100 mm thick for drain in cement concrete 1:1.5:3 using graded granite jelly 20mm and down size with	Sqm	69.21

With respect to the above subject & name of the work, we have inspected the work and the Quantity and Quality of above mentioned items of the work was found to be completed satisfactorily for the 1st and Final bill

Thanking you,

ಸಹಾಯಕ ಕಾರ್ಯದರ್ಶಿ ಅಭಿಯಂತರ
ಯಲಹಂಕರ ಉಪನಗರ ಉಪವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಕೆ. ಬೆಂಗಳೂರು-560056
For Newzen Consultants Bangalore

With Regards,
Newzen Consultants Bangalore



NO.NC/QC/YD/2020-21/YSD-CC

Date: 20-05-2020

To,
The Executive Engineer,
Yelahanka Division
Bangalore.

"FREQUENCY AND QUALITY REPORT"

Dear Sir,

Subject: Regarding Quality Report for the below mentioned work.

Name of Work: Construction of CC road in Ward No. 03 Attur, Yelahanka

Item No	Description of work	Unit	Qty	No of Samples Tested	Standards
1	Construction of granular sub-base Grading-V as Sub-base and drainage layer by providing	Cum	91.40	1	Per 400 cum
2	KSRRB M2100-10. Providing and laying Plain cement concrete of mix 1:3:6 with OPC @	Cum	241.92	3	Per 100 cum
3	Constructing un-reinforced, plain cement concrete for pavements using Grade	Cum	235.30	10	Per 50 cum
4	Providing and fixing pre cast solid cement concrete kerb stones made out of C.C. 1:2:4	Nos	735.00	4	Per 500 Nos

With respect to the above subject & name of the work, we have inspected the work and the Quantity and Quality of above mentioned items of the work was found to be completed satisfactorily for the 1st and Final bill

Thanking you,

ಸಹಾಯಕ ಅಭಿವೃದ್ಧಿ ಅಧಿಕಾರಿ
ಯಂತ್ರೋಪಕರಣ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಸಿ. ಬೆಂಗಳೂರು-106

With Regards,
For Newzen Consultants Bangalore